

Top Ten

Elevator Violation

The State Elevator Inspectors perform annual on-site surveys of all elevators. The following list contains items to be addressed by the building owner/manager prior to the arrival of the a State Elevator Inspector.

Safety Notice

1. Perform test of fireman's return features monthly and
 maintain a written record of the test results.
2. Display current certificate in elevator car.
3. Must make emergency telephone operable.
4. Must make emergency lighting operable.
5. Remove all non-elevator related materials from elevator
 machine room.
6. Maintain elevator machine room fire extinguisher and keep
 current at all times.
7. Install elevator pit ladder.
8. Install self-closing, self-locking elevator machine room door.
9. Install pit and car top light guards.
10. Install non-combustible pit sump pump cover.

If you have questions regarding any of the top ten items or your own safety/corrective actions lists, please do not hesitate to contact a service sales representative in your local O'Keefe Elevator Company office.